



Certificate of Compliance

This certificate is issued for the following:

PIPE HANGERS

<i>Product Designation</i>	<i>Hanger Rod Size, mm</i>	<i>Component Description</i>	<i>For Nominal Pipe Sizes, in.</i>
FRSP 524036	M10	Sprinkler Clamp	3/4
FRSP 524037	M10	Sprinkler Clamp	1
FRSP 524038	M10	Sprinkler Clamp	1 1/4
FRSP 524039	M10	Sprinkler Clamp	1 1/2
FRSP 524040	M10	Sprinkler Clamp	2
FRSP 524041	M10	Sprinkler Clamp	2 1/2
FRSP 524042	M10	Sprinkler Clamp	3
FRSP 524043	M10	Sprinkler Clamp	4
FRSP 524044	M12	Sprinkler Clamp	5
FRSP 524045	M12	Sprinkler Clamp	6
FRSP 524046	M16	Sprinkler Clamp	8
TZA 524047*	M10	Profile Hanger	3/4 through 2

* Approval limited to minimum allowable steel deck thickness of 0.75 mm and greater with the side punched holes on the steel deck a minimum of 44 mm from the bottom of the steel deck span.

Prepared for:

Fischerwerke GmbH & Co KG
Weinhalde 14-18
D-72178 Waldachtal
Germany

FM Approvals Class: 1951, dated September 2003

Approval Identification: 0003051510

Approval Granted:

February 4, 2014

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

Richard B. Dunne
Group Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062



Member of the FM Global Group